



NOTE
 TAPS IN STAGGERED CONFIGURATION AT
 10 O'CLOCK OR
 2 O'CLOCK POSITION

NOTES:

1. SANITARY SEWER SERVICE TAPS SHALL BE LOCATED ON THE MAIN AT THE 2 O'CLOCK OR 10 O'CLOCK POSITION.
2. THE MINIMUM DISTANCE BETWEEN ANY TWO CONSECUTIVE FITTINGS SHALL BE 3 FEET, MEASURED BETWEEN FITTING CENTERLINES.
3. SANITARY SEWER SERVICE TAPS SHALL NOT BE MADE WITHIN 3 FEET OF A PIPE JOINT, OR 5 FEET FROM EDGE OF MANHOLE BASE.
4. A MAXIMUM OF FOUR SERVICE TAPS ARE ALLOWED PER 20 FOOT LENGTH OF PIPE.
5. ALL SANITARY SEWER TAPS SHALL USE "WYE" STYLE FITTINGS. TEES ARE NOT ALLOWED.
6. SERVICE CONNECTIONS TO MANHOLES SHALL BE PERFORMED IN ACCORDANCE WITH THE "SERVICE CONNECTION TO DEAD-END MANHOLE" CONSTRUCTION DETAIL.

No XREFs
 i:\Key_Std\SAS\Details\dwg\Sasd-PRI-1s.dwg

Kennedy/Jenks Consultants
Engineers & Scientists
 143 Union Boulevard
 Suite 600
 Lakewood, CO 80228
 303.965.3636 TEL
 303.965.3800 FAX



SOUTH ARAPAHOE
 SANITATION DISTRICT
 www.southarapahoe.org

SERVICE CONNECTIONS TO NEW CONSTRUCTION