



NOTES:

1. CASING SPACERS SHOULD BE INSTALLED WITHIN ONE FOOT OF BELL AND SPIGOT JOINT AND ONE IN CENTER OF PIPE.
2. PROVIDE UNIFLANGE RESTRAINED CASING SPACERS 1300 & 1390 OR EQUAL.

PIPE DIA.	CASING SPACER DIMENSION	CASING O.D.	PIPE WALL THICKNESS
6"	13.375"	16"	0.375"
8"	17.125"	18"	0.375"
12"	21.875"	24"	0.375"
16"	28.375"	30"	0.375"
24"	38.250"	40"	0.375"

No_XREFs I:\Key_Std\SAS\Details\dwg\Sasd-PUB-19s.dwg

Kennedy/Jenks Consultants
Engineers & Scientists

143 Union Boulevard
Suite 600
Lakewood, CO 80228
303 985 3636 TEL
303 985 3800 FAX



SOUTH ARAPAHOE
SANITATION DISTRICT

www.southarapahoe.org

**RESTRAINED
CASING SPACERS
DETAIL**

DRAWING NO.: SASD-PUB-19S DATE: 5/08